



Food Program Official Inspection Report

Siskiyou County Community Development Department
 Environmental Health Division
 806 S. Main Street
 Yreka, California 96097
 phone: (530) 841-2100, fax: (530) 841-4076

Facility Name: Gonzo's Breakfast House	Permit # 000266
Address: 715 N Main Street, Yreka CA 96097	
Permit Holder: Gustavo Gonzalez and Marilou Arreola	Permit To Operate: <input checked="" type="radio"/> Valid <input type="radio"/> Not Valid
Phone: 530-605-9191	E-mail: gusgonzo@hotmail.com
Food Safety Certified Employee: Marilou Arreola	Expiration Date: 02/2029

		MAJ	OUT	COS	
					The marked items represent Health Code violations and must be corrected as follows:
Protection Time/ Temp.	1		X	X	<p style="text-align: center; margin: 0;">ROUTINE INSPECTION CONDUCTED ON THIS DATE</p> <p>1) Observed sliced and shredded cheese at 53F at the deli-prep cooler. Hold cold foods at 41F or below. Dairy can be held at 45F or below. Corrected during inspection.</p> <p>2) Observed cooked potatoes at 72F covered and cooling in the refrigerator. Ensure one of the following methods are utilized to rapidly cool foods: placed in a shallow pan, separating food into smaller/thinner portion, using rapid cooling devices, using ice paddles, using ice as an ingredient, inserting containers in an ice bath and stirring frequently. Correct immediately.</p> <p>3) Observed raw meats and eggs store above ready to eat food in the reach in refrigerator in the kitchen and cabinet below the deli-prep cooler. Ensure ready to eat food is stored above raw meat. Corrected during inspection.</p> <p>13) Observed numerous working clothes stored on the prep table. Place working and not heavily soiled wash cloths in the sani-bucket when not is used. Corrected onsite.</p> <p>14) Observed Household Use Only equipment (blender and crock pot). Utilize equipment that has been ANSI or NSF certified. Discontinue use or replace with ANSI/NSF certified equipment. Submit manufacturers cut/spec sheet for preapproval prior to purchase.</p> <p>14, 30) Observed bare wood throughout the prep area and wall in the dry storage area. Maintain the finishes to be smooth, cleanable, nonabsorbent, and durable. Repair or correct within 90 days.</p> <p>14) Observed the prep sink and ice machine tubes discharging into the floor sink without a 1" air gap. Ensure these discharge pipes/tubes are plumbed indirectly with a 1" air gap. Repair or correct within 90 days.</p> <p>14) Observed the air gap to the liquid discharge pipe for the 3-compartment sink or dishwasher is far from the floor sink causing liquid and waste to splash outside the floor sink. Lengthen the indirect plumbing (atleast 1" air gap) closer to the rim of the floor sink.</p>
	2		X		
	3		X		
	4				
	5				
	6				
	7				
Food Storage	8				
	9				
	10				
	11				
Uten./Equip.	12				
	13		X		
	14		X		
Employee	15				
	16				
	17				
	18				
Water	19				
	20				
	21				
Waste	22				
	23				
Vermin	24				
	25				
Facilities	26				
	27				
	28				
	29				
	30				
	31				
	32				
Misc.	33				
	34				
	35				
	36				

MAJ = Major violation OUT = Out of compliance COS = Corrected on-site	
Received By (Print): Marilou Arreola	Received by (Signature): _____ Date: 03/14/2024
REHS (Print): Chalyn Dewey	REHS (Signature): _____ Phone: 530-841-2112

Facility Name: Gonzo's Breakfast House

The marked items represent Health Code violations and must be corrected as follows:

Received By (Print): Marilou Arreola Received by (Signature): Date: 03/14/2024

REHS (Print): Chalyn Dewey REHS (Signature): Phone: 530-841-2112

Facility Name: Gonzo's Breakfast House

The marked items represent Health Code violations and must be corrected as follows:

Received By (Print): Marilou Arreola	Received by (Signature):	Date: 03/14/2024
---	--------------------------	---------------------

REHS (Print): Chalyn Dewey	REHS (Signature):	Phone: 530-841-2112
-------------------------------	-------------------	------------------------

Facility Name: Gonzo's Breakfast House

The marked items represent Health Code violations and must be corrected as follows:

Received By (Print):
Marilou Arreola

Received by (Signature):

Date:
03/14/2024

REHS (Print):
Chalyn Dewey

REHS (Signature):

Phone:
530-841-2112